

# certificate of conformity

## Konformitätsbescheinigung

**CW-8501DL0124**

Registration Number  
Registriernummer

|                                                                       |                                                                                                                                                                                                      |
|-----------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Field of Application</b><br><i>Anwendungsbereich</i>               | products of water supply<br><i>Produkte der Wasserversorgung</i>                                                                                                                                     |
| <b>Owner of Certificate</b><br><i>Zertifikatinhaber</i>               | N.T.M. S.p.A.<br>Via John Maynard Keynes, 15/17, I-25030 Brandico (BS)                                                                                                                               |
| <b>Distributor</b><br><i>Vertreiber</i>                               | N.T.M. S.p.A.<br>Via John Maynard Keynes, 15/17, I-25030 Brandico (BS)                                                                                                                               |
| <b>Product Category</b><br><i>Produktart</i>                          | installation systems and system joints: drinking water installation system (8501)                                                                                                                    |
| <b>Product Description</b><br><i>Produktbezeichnung</i>               | drinking water installation system consisting of press connectors, compression connectors and push connectors made of metal and multilayer pipes PE-Xb/Al/PE-Xb                                      |
| <b>Modell</b><br><i>Modell</i>                                        | WINNY-AL                                                                                                                                                                                             |
| <b>Test Reports</b><br><i>Prüfberichte</i>                            | type testing: V285/19.2 from 11.03.2020 (IMA)<br>type testing: V431/17.2 from 23.05.2019 (IMA)                                                                                                       |
| <b>Test Basis</b><br><i>Prüfgrundlagen</i>                            | DIN EN ISO 21003-2 (01.11.2008)<br>DIN EN ISO 21003-3 (01.11.2008)<br>DIN EN ISO 21003-5 (01.11.2008)<br>DIN CEN ISO/TS 21003-7 (01.09.2019)<br>UBA METALLE (21.11.2018)<br>UBA ELASTOM (16.03.2016) |
| <b>Date of Expiry / File No.</b><br><i>Ablaufdatum / Aktenzeichen</i> | 11.03.2025 / 20-0122-WKE                                                                                                                                                                             |

This certificate confirms the compliance with the indicated standard(s). It makes no statement about the fulfillment of legal requirements in Germany or other European Member States

11.06.2020 Fk A-1/2

Date, Issued by, Sheet, Head of Certification Body  
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



Deutsche  
Akkreditierungsstelle  
D-ZE-16028-01-05

DVGW CERT GmbH  
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3  
53123 Bonn

Tel. +49 228 91 88 - 888  
Fax +49 228 91 88 - 993

www.dvgw-cert.com  
info@dvgw-cert.com

| <b>Type</b><br><b>Typ</b> | <b>Technical Data</b><br><b>Technische Daten</b> | <b>Remarks</b><br><b>Bemerkungen</b>                                            |
|---------------------------|--------------------------------------------------|---------------------------------------------------------------------------------|
| WINNY-AL                  | nominal diameter: 16,0 x 2,00 mm                 | press connectors (pressing contour TH), compression connectors, push connectors |
| WINNY-AL                  | nominal diameter: 20,0 x 2,00 mm                 | press connectors (pressing contour TH), compression connectors, push connectors |
| WINNY-AL                  | nominal diameter: 26,0 x 3,00 mm                 | press connectors (pressing contour TH), compression connectors, push connectors |
| WINNY-AL                  | nominal diameter: 32,0 x 3,00 mm                 | press connectors (pressing contour TH), compression connectors                  |

**Hints of Utilization / Remarks****Verwendungshinweise / Bemerkungen**

only to use with connectors: press, compression and push connectors made of metal, type M-MV, manufacturer: N.T.M. S.p.A., I-25030 Brandico

pipe: multilayer pipe PE-Xb/Al/PE-Xb, listed in test report: IMA V431/17.2

type variations:

Winny-Al Press system: Line 700/700S/700V

Winny-Al Comp system: Line 900

Winny-Al Push system: Line 7900